

NOTE #1: Pump should be located within close proximity to the tank.

NOTE #2: Pump plumbing should be run with schedule 40 or better with thread by slip adapters at pump outlet, pump control and bulkhead fittings. A union is advisable for easy removal.

NOTE #3: It may be necessary to pipe the tank overflow such that water runoff does not erode area around tank.

