

BILL OF MATERIALS:

1. PRESSED STEEL RF FRAME TO BE INSTALLED AT FINISHED FLOOR HEIGHT AND GROUNDED (DO NOT EMBED IN FLOOR FINISHING).
2. HOLLOW METAL RF DOOR.
3. SPRING-BRONZE WEATHERSTRIPPING FITTED AND FASTENED AT HEADER/JAMBS AND BOTTOM OF DOOR INSTALLER AT SITE.
4. RFI-SHIELDING PERIMETER SEALS TO BE FITTED AND FASTENED TO HEADER AND JAMBS BY INSTALLER ON SITE.
5. RFI-SHIELDING SURFACE-MOUNTED DROP-BOTTOM TO BE FITTED AND FASTENED BY INSTALLER AT SITE.
6. 1/2" HIGH STEPPED RFI-SHIELDING THRESHOLD TO BE FITTED, FASTENED, AND GROUNDED BY INSTALLER AT SITE.
7. FINISHED FLOOR. (TOP OF FLOOR FINISHING MATERIAL (IE: TILE, CARPET, ETC.)

GENERAL NOTES:

8. FRAME/DOOR PREPPED FOR 1 PAIR OF CAM-LIFT HINGES.
9. DOOR TO HAVE CONDUCTIVE TAPE/PAIN MASK WHERE WEATHERSTRIP AND RF SEALS MAKE CONTACT. REMOVE MASK LAYER AFTER FINISH PAINTING.
10. FRAME/WALL INTERFACE IS DEPENDANT ON WALL CONSTRUCTION. CONSULT AMBICO ENGINEERING.
11. PERFORMANCE: MINIMUM 60dB ATTENUATION FROM 10MHz TO 1GHz

