

**ASSA ABLOY**

ASSA ABLOY Entrance Systems  
1900 Airport Road  
Monroe, NC 28110  
Phone: 1-866-237-2687  
specdesk.na.besam@assaabloy.com

BESAM RD4A-1  
REVOLVING DOOR SYSTEM  
SECTION VIEW

MODEL #	OUTER RADIUS ( D )	INNER RADIUS ( E )	OVERALL FASCIA HEIGHT
RD4A-1-6	37 1/8"	35 3/8"	94 1/2"
RD4A-1-7	43 1/16"	41 5/16"	94 1/2"
RD4A-1-8	49"	47 1/4"	94 1/2"

NOTES:

**INSTALLATION REQUIREMENTS:**  
BESAM REQUIRES THE FLOOR FLAT TO WITHIN 1/4" TOT L VARIATION WITHIN THE FOOTPRINT OF THE DOOR SYSTEM. BESAM "RD" SERIES DOORS ARE DESIGNED TO MOUNT ON A FINISHED FLOOR SURFACE, THE FLOOR AREA SHOULD BE CAPABLE SUPPORTING WEIGHT LOADS OF 800 lbs AT THE CENTER OF THE DOOR (CENTER SHAFT CONNECTION), AND 1000 lbs LOAD EVENLY DISTRIBUTED ACROSS THE OUTSIDE DRUM WALLS.

**ACTIVATION:**  
ACCESS CONTROL SYSTEMS (CARD READER, ETC.) TO SUPPLY SIGNAL TO THE REVOLVER CONTROL TO BEGIN ROTATION OF THE

DOOR SYSTEM, BY OTHERS. BESAM DOOR SYSTEM WILL SUPPLY OUTPUT SIGNAL TO ACCESS CONTROL SYSTEM AT PASSAGE WAS COMPLETED. PASSAGE IN TWO DIRECTIONS CAN BE CONDUCTED SIMULTANEOUSLY.

**ACCESS CONTROL FEATURES:**  
1-WAY SECURITY DETECTION BY OVERHEAD SENSORS (ANTI-TAILGATING).  
PASSAGE BY UNAUTHORIZED PERSON WILL CAUSE THE DOOR TO STOP ROTATING, VOICE ACTIVATION WILL ANNOUNCE "SECURITY VIOLATION - DOORS WILL REVERSE", THE DOOR WILL THEN REVERSE DIRECTION TO ALLOW UN-AUTHORIZED PERSON TO EXIT THE DOOR. DOOR SYSTEM WILL THEN RESUME OPERATION TO ALLOW AUTHORIZED PERSON TO COMPLETE PASSAGE.

**SAFETY FEATURES:**  
AN OBSTRUCTION FORCE CAUSING ROTATION TO SLOW OR STOP WILL ACTIVATE THE CURRENT SENSING DOOR WING SAFETY CIRCUIT. THIS CIRCUIT WILL STOP THE ROTATION ACTION THEN RESUME OPERATION, IF THE CAUSE OF THE STOP OR SLOW DOWN REMAINS THIS PAUSE AND RESUME ACTION WILL REPEAT TWO ADDITIONAL TIMES. IF THE CAUSE HAS STILL NOT BEEN CLEARED AT THIS POINT, THE DOOR SYSTEM WILL SHUT DOWN TILL A SUPERVISORY START UP SEQUENCE IS COMPLETED. DRUM WALL MOUNTED COMPRESSIBLE SAFETY SWITCHES WILL STOP ROTATION IF PRESSURE IS APPLIED AND WILL REVERSE THE DOOR TO THE "O" POSITION WHEN AN OBJECT IS LODGED BETWEEN THE DRUM WALL AND A DOOR WING. EMERGENCY STOP BUTTON, WHEN ACTIVATED, WILL STOP ROTATION OF THE DOOR UNTIL A SUPERVISED RESET IS CONDUCTED.

**STANDARD FEATURES:**  
MICROPROCESSOR CONTROL SYSTEM WITH SELF-MONITORING CHECK CIRCUITS, POSITIVE SPEED CONTROL FOR PROPER DOOR SPEED OPERATION. FOD PROGRAMMED CONTROL DEVICE WITH OPERATOR KEYPAD TO CONTROL THE DOOR OPERATION, DISPLAY OPERATIONAL AND ERROR CODES FOR VISUAL DIAGNOSTICS OF THE DOOR SYSTEM.  
DOORS ARE EQUIPPED WITH RECESSED LOW VOLTAGE HALOGEN LIGHTS, 6 PER DOOR.  
OUTSIDE DRUM WALL GLASS TO BE 1/2" LAMINATED CURVED GLASS. ROTATING DOOR GLASS TO BE 1/2" LAMINATED CLEAR GLASS.  
INTERIOR CEILING TO BE WOOD SUBSTRATE WITH WHITE LAMINATE SURFACE.  
DUST PROTECTION ROOF.

**TECHNICAL DATA:**  
POWER REQUIRED, (1) 208VAC TO 240VAC, 20 AMP DEDICATED CIRCUIT AND (1) 120VAC 20 AMP CIRCUIT 2 GANG (4 RECEPTACLE) OUTLET BOX FOR CONNECTION OF VOICE BOX AND SECURITY SENSORS.  
NORMAL SPEED ADJUSTMENT, INDEPENDENTLY ADJUSTABLE FROM 1 TO 5 R.P.M.



**FINISHES: (SPECIFY):**  
\_\_\_ CLEAR ANODIZED.  
\_\_\_ DARK BRONZE ANODIZED  
\_\_\_ POWDER COAT PAINTED \_\_\_\_\_  
\_\_\_ KYNAR PAINT # \_\_\_\_\_  
\_\_\_ STAINLESS STEEL CLAD  
\_\_\_ #8 MIRROR FINISH  
\_\_\_ #4 SATIN FINISH  
\_\_\_ OTHER CLAD \_\_\_\_\_

DWG NO.	RD4A-2	EMERGENCY BREAKAWAY SYSTEM FOR ROTATING DOORS CAN BE INTEGRATED WITH THE FIRE ALARM SYSTEM.
DRN BY	D.D.D.	DATE 5/12/99
CHK BY	DATE	REV. D DATE 5/30/14

BESAM RD4A-1 1 WAY ACCESS CONTROL  
REVOLVING DOOR SYSTEM  
SECTION VIEW

**ASSA ABLOY**

ASSA ABLOY Entrance Systems  
1900 Airport Road  
Monroe, NC 28110  
Phone: 1-866-237-2687  
specdesk.na.besam@assaabloy.com



VERTICAL SECTION

HORIZONTAL SECTION