

4

3

2

1

CIM PREVIOUSLY INSTALLED ON RADIATOR LEDGE

4EVASEAL FABRIC BACKED TAPE 4"

CIM 1000TG

STAINLESS BOX AROUND CONDUIT

4EVASEAL FABRIC BACKED TAPE 4"

GROUT

- NOTES: 1. PRIME CONCRETE AND STAINLESS STEEL WITH CIM EMT EPOXY PRIMER.  
2. SEVERLY ABRASE PREVIOUSLY INSTALLED CIM AND APPLY  
CIM VOC COMPLIANT BONDING AGENT PER MANUFACTURER'S  
INSTRUCTIONS.  
3. PREPARE SURFACES PER CIM INSTRUCTIONS.



TITLE

NMAAHC-SS SLEEVE DETAIL A

SIZE

DWG NO

REV

SCALE NONE

SHEET 1 OF 1

4

3

2

1