

## NOTES:

- The Elevator Machine Room Location And Layout Must Meet The Code Requirements Defined By The Local Authority Having Jurisdiction.
- 30" Wide x 36" Deep Clear Working Space In Front Of The Motor Controller And Disconnects As Required By National Electrical Code (NFPA70).
- The Disconnects and Light Switch Must Be Located On The Strike Side Of The Machine Room Door.
- The Hydraulic Power Unit Must Be Located Within 40' Of The Cylinder.
- The Machine Room Must Be Free Of All Equipment Not Related To The
- 6) The Minimum Machine Room Headroom is 7' 0".
- The Machine Room Must Be Maintained Between 50° to 80° F, with 7) relative humidity from 5 to 95%, non-condensing.

Square D - H321N Or Equivalent 3 Pole W/ Auxiliary Contact

**Car Light Disconnect** Square D - G221N Or Equivalent.

SYMMETRY ELEVATING

