
## THIS DRAWING IS FOR PLANNING PURPOSES ONLY DO NOT USE FOR **CONSTRUCTION**



- APPLICATION, THE PIT MUST BE PROVIDED WITH AN ADEQUATE DRAIN.
  HOISTWAY WALLS MUST BE PLUMB, SQUARE, AND TURNOVER FINISHED BEFORE
  UNIT INSTALLATION.
- UPPER AND LOWER DOORS OR GATES MUST BE INSTALLED FLUSH TO THE INTERIOR
- UPPER AND LOWER DOORS OR GATES MUST BE INSTALLED FLUSH TO THE INTERIOR OF THE HOISTWAY.

  80 INCH MINIMUM HEAD CLEARANCE IS REQUIRED THROUGHOUT TRAVEL. HOISTWAY LIGHTING IS PROVIDED BY OTHERS. SFITC REQUIRED ON THE PLATFORM SURFACE THROUGHOUT TRAVEL. AN AUXILIARY LIGHT CONSISTING OF NO FEWER THAN 2 LAMPS PRODUCING. 2FITC ON THE FLOOR AND CONTROLS FOR NOT LESS THAN 4 HOURS, AND ACTIVATED AUTOMATICALLY IN THE EVENT OF A POWER OUTLAGE.
- MAIN TOWER MUST BE FASTENED TO THE WALL AND FLOOR WITH ANCHORS SUITABLE TO THE SITE CONDITIONS, AND CAPABLE TO WITHSTAND THE FORCES PLACED UPON THEM.
  ALL BLOCKING IS PROVIDED BY OTHERS.
- ALL BLOCKING IS PROVIDED BY OTHERS.
  THE DISCONNECT (PROVIDED BY OTHERS) SHALL BE A LISTED DEVICE
  CONFORMING TO NFPA 70 / NEC 620.51 AND SHALL BE INSTALLED WITHIN SIGHT OF
  THE MOTOR CONTROLLER. THE DISCONNECTING MEANS SHALL BE EXTERNALLY
  OPERABLE, HAVE PERMANENT MEANS OF LOCKING THE DEVICE IN THE OPEN
  POSITION, AND BE LABELED WITH THE LOCATION OF THE SUPPLY SIDE OVERCURRENT PROTECTION MEANS.

♦ SYMMETRY		SYMMETRY ELEVATING SOLUTIONS PH 877-375-1428	
TITLE			SCALE
EL-ST-TL-36x54-PIT			NONE
DRAWN BY	ORIGINAL DATE	DRAWING NO.	REV
CR	12/21/20	VPL079	0
JOB INFORMATION THIS DRAWING IS FOR PLANNING PURPOSES ONLY, DO NOT USE FOR CONSTRUCTION			