



## DOOR THRESHOLD

5

D.2

ARCH. DETAIL REF.:  
ARCH. SHEET REF.:

**DEFENSELITE®**  
**BULLET SHIELD™**

### PARTS DESCRIPTION

- ① #12x1" H.H. TEK SCREWS  
4" FROM EACH END & 12"-14" O.C.
- ② #12x2" PAN HEAD SDS TT27 COUNTERBORE HEAD,  
1" FROM EDGE ON VERTICALS,  
3" FROM EDGE ON HORIZONTALS,  
14"-16" O.C. THEREAFTER.  
REQUIRES 3/4" HOLE DRILLED IN MS1250-1.250 BULLETSHIELD.
- ③ 1" WIDE HIGH BOND TAPE  
1" TUBE TO EXISTING FRAMING.
- ④ 3/4" WIDE HIGH BOND TAPE  
1" TUBE TO NEW MS1250-1.250 BULLETSHIELD.
- ⑤ 3/4" WIDE HIGH BOND TAPE  
NEW 1" ANGLE TO NEW MS1250-1.250 BULLETSHIELD.
- ⑥ 1" x 1" x .125 (6063) ALUM. TUBE
- ⑦ 1" x 2" x .125 (6061) ALUM. ANGLE
- ⑧ DOW 995 PERIMETER SEALANT
- ⑨A MS1250-1.250 BULLETSHIELD (THREAT SIDE)  
⑨B BR1000-1.000 BULLETSHIELD (NON-THREAT SIDE)
- ⑩ VENT CAP - P/N FV1 (BLACK), (GREY), OR (WHITE).  
6" FROM EACH END & 24" O.C.  
STAGGERED FOR SYMMETRY ON EACH SIDE.
- ⑪ #12x1-3/4" PAN HEAD SDS TT25 COUNTERBORE HEAD,  
1" FROM EDGE ON VERTICALS,  
3" FROM EDGE ON HORIZONTALS,  
14"-16" O.C. THEREAFTER,  
REQUIRES 3/4" HOLE DRILLED IN BR1.000-1.000 BULLETSHIELD.



VENT CAP INSTALLED AFTER ALL  
FRAME FASTENING AND  
VENTILATION WORK IS COMPLETED.