



T
4"
5"
6"
7"
8"

- NOTES:
1. IF JOINT SEALANTS ARE REQUIRED, THEY ARE SPECIFIED AS A SILICONE SEALANT IN ORDER TO CONFORM TO THE PANEL'S ASTM E-119 FIRE RESISTANCE RATING. SEALANT IS REQUIRED IN BOTH JOINTS IF THE PANEL IS EXTERIOR AND EXPOSED TO WIND AND DRIVEN RAIN.
 2. IF PANEL IS USED AS AN INTERIOR PARTITION, NO SEALANT IS NEEDED UNLESS A VAPOR BARRIER IS REQUIRED. IF VAPOR BARRIER IS REQUIRED, THE SEALANT SHOULD BE APPLIED ON THE WARMER SIDE OF THE PANEL.

COMMERCIAL AND INDUSTRIAL

VERTICAL JOINT DETAIL THERMALS SAFE PANEL
© 2016 Metl-Span, an NCI Building Systems company. All rights reserved.

TSW03020
DATE: Nov. 9, 2016