



- NOTES:
1. FIRE PROTECTION OF THE CORNER STRUCTURAL MAY BE REQUIRED PER THE BUILDING CODE AND IS NOT BY "METL-SPAN".
 2. TO CONFORM TO THE REQUIREMENTS OF THE ASTM E-119 FIRE RESISTANCE RATING, THE FILLER INSULATION MUST HAVE AN APPROVED CLASSIFICATION MARKING FOR SURFACE BURNING CHARACTERISTICS OR FIRE RESISTANCE.
 3. * FASTENER TYPE IS SUBJECT TO THE SUPPORT STRUCTURAL MATERIAL AND THE PANEL THICKNESS.

STACK JOINT TRIM		STACK JOINT ANGLE
T	PIECE MARK	'L'
4"	F5761	2½"
5"	F5763	3"
6"	F5765	3½"
7"	F5767	4"
8"	F5769	4½"

COMMERCIAL AND INDUSTRIAL

VERTICAL STACK JOINT THERMSAFE PANEL

TSW03022
DATE: Nov. 9, 2016