Boral Steel® Architectural Details are divided into three (3) categories based on the install method used:

BATTEN (Panel is exposed fastened & mounted onto a wood 2x2 batten or steel hat channel)

DIRECT (Panel is exposed fastened & mounted Direct-to-the roof-deck)

GRANITE-RIDGE Shingle (Panel is hidden fastened & mounted Direct-to-the roof-deck)

*Batten Fasteners omitted for clarity.
See fastening drawings for panel and batten attachment.


Battens: to be nominal 2"x2" spruce pine fir #2 or better.

Fastener number, spacing and size as per fastener chart.

Install using appropriate Boral Steel "Batten Spacers". **Spacing between first two battens will vary to insure panel layout.**

Panels: Install bottom panel to extend past fascia +- ½". Seal and chip screws at top surface of panel.

Boral Steel Screws to be minimum 2". Fasteners are to be set flush and tight to the surface of the panel. (space between panel and screw head shown for clarity)



Roofing Underlayment: Wrap min. 1" over finish edges.

Batten Spacing

PINE-CREST Shake: 14 1/4"

PACIFIC Tile: 14 ¹/₄"

BARREL-VAULT Tile: 14"

Profiles:
PINE-CREST Shake
BARREL-VAULT Tile
PACIFIC Tile

BATTENPanel Fastening

Boral Steel Stone Coated Roofing 7575 Irvine Ctr Dr Suite 100, Irvine, CA 92618

Drawings are not to scale