

SECTIONAL VIEW - ZENITH BIFOLD RESIDENTIAL-3654 (1L)

Diagram illustrating the sectional view of the Zenith Bifold Residential-3654 (1L) system, showing the lifting beam, custom rail, and shaft height.

Key components and dimensions labeled:

- LIFTING BEAM MIN SWL 4000lb
- MIN. TO BOTTOM OF LIFTING BEAM
- DOORS BY OTHERS
- LANDING 2
- LANDING 1
- DOORS BY OTHERS
- 80" [2032mm]
- 30" [762mm] TYP
- 36" [914mm] TYP
- 96" [2438mm] RAIL
- CUSTOM RAIL
- TOTAL SHAFT HEIGHT
- OVERSPEED GOVERNOR TO SAFETY BRAKE ON SLING
- [254mm] PLT

PLAN VIEW - ZENITH BIFOLD RESIDENTIAL-3654 (1L)

H/W CEILING

1 RUNNING CLEARANCE

62" [1575mm] FINISHED RUNWAY LENGTH

57 1/2" [1461mm] OVERALL CAB LENGTH

54" [1372mm] CLEAR CAB DEPTH

34 1/2" [876mm] IBG

31" [787mm] RAIL BRKT

18 3/8" [467mm] LIFTING BEAM MIN SWL 4000lb

59 3/8" [1508mm] FINISHED RUNWAY WIDTH

37 1/8" [943mm]

14" [356mm]

3 1/2" [89mm]

32 1/4" [819mm] R3 LOAD ON BUFFERS R4/R5 LOAD ON RAILS

9 1/4" [234mm]

2 3/8" [61mm]

11 3/16" [284mm]

5 3/8" [139mm]

R1, R2, R3, R4, R5

***GENERAL**

HOISTWAY- THE HOISTWAY MUST BE IN ACCORDANCE WITH "SAFETY CODE FOR ELEVATORS AND ESCALATORS" (ASME A17.1) AND ALL STATE AND LOCAL CODES.

PLUMB HOISTWAY- DUE TO CLOSE RUNNING CLEARANCES OWNER/AGENT MUST ENSURE THAT HOISTWAY AND PIT (WHERE PROVIDED) ARE LEVEL, PLUMB AND SQUARE AND ARE IN ACCORDANCE WITH THE DIMENSIONS ON THESE DRAWINGS.

MINIMUM OVERHEAD CLEARANCE- OWNER/AGENT MUST ENSURE MINIMUM OVERHEAD CLEARANCE IS IN COMPLIANCE WITH CODES.

CONSTRUCTION SITE- OWNER/AGENT TO PROVIDE ALL MASONRY, CARPENTRY AND DRYWALL WORK AS REQUIRED AND SHALL PATCH AND MAKE GOOD (INCLUDING FINISH PAINTING) ALL AREAS WHERE WALLS/FLOORS MAY REQUIRE TO BE CUT, DRILLED OR ALTERED IN ANY WAY TO PERMIT THE PROPER INSTALLATION OF THE LIFT.

DIMENSIONS

CONTRACTOR/CUSTOMER TO VERIFY ALL DIMENSIONS AND REPORT ANY DISCREPANCIES TO OUR OFFICE IMMEDIATELY.

***STRUCTURAL**

FLOOR/SUPPORT WALL LOADS- STRUCTURE TO ANCHOR A CRANK SHAFT AND SAFETY HARNESS, WHERE APPLICABLE/NEEDED, TO BE PROVIDED BY CONTRACTOR. CONTRACTOR TO ASSURE THAT BUILDING AND SHAFT WILL SAFELY SUPPORT ALL LOADS IMPOSED BY THE LIFT EQUIPMENT. REFER TO THE TABLES ON THIS DRAWING FOR LOADS IMPOSED BY THE EQUIPMENT.

***MACHINE ROOM (WHERE REQUIRED)**

LOCATION / ACCESS- MACHINE ROOM LOCATED AT THE LOWEST LEVEL ADJACENT TO HOISTWAY, UNLESS SHOWN OTHERWISE ON THE LAYOUT DRAWINGS. FIELD ADJUSTMENT BY INSTALLER MAY BE NECESSARY TO MEET JOB SITE CONDITIONS OR REGULATIONS. MACHINE ROOM DOOR IS TO BE LOCKABLE AND IS TO MEET THE REQUIREMENTS OF THE AUTHORITY HAVING JURISDICTION.

SLEEVES FOR ELECTRIC LINES- FROM MACHINE ROOM TO HOISTWAY AS REQUIRED (POSITION PER INSTALLER'S INSTRUCTIONS).

10 1/4" [260mm]

36" [914mm]
CLEAR (INSIDE CAB)

37 1/2" [953mm]
OVERALL CAB WIDTH

3 5/16" [89mm]

6mm

TABLE 3

	DISCONNECT SIZE	ONE DELAY FUSE SIZE	VOLTS	PHASE	FLA
MOTOR & EQUIP.	60 AMPS	40 AMPS	230 volt	Single Phase	35.0 AMPS
CAB LIGHTS	15 AMPS	15 AMPS	115 V	Single Phase	

***ELECTRICAL**

POWER SUPPLY- (SEE SPECIFICATIONS) LOCKABLE FUSED DISCONNECT WITH AUXILIARY CONTACT TO BRAKE THE BATTERY FEED, OR CIRCUIT BREAKERS WITH A 3-POLE BREAKER FOR BATTERY FEED REQUIRED, IN COMPLIANCE WITH ELECTRICAL CODE, AS FOLLOWS:

(LOCATED ON WALL ON LOCK JAMB SIDE OF MACHINE ROOM DOOR)

PERMANENT POWER- BEFORE INSTALLATION CAN BEGIN, PERMANENT POWER MUST BE SUPPLIED.

LIGHTING- THE ILLUMINATION SHALL BE NOT LESS THAN 200 LX (19 FC) AT THE FLOOR LEVEL IN ALL MACHINE ROOMS AND MACHINERY SPACES. ENSURE AT LEAST 100 LX (10 FC) AMBIENT LIGHTING OVER LIFT AREA.

PHONE- NEED A DEDICATED PHONE LAND LINE

***ENTRANCES**

FASCIA PANEL BELOW UPPER LEVEL ENTRANCE- WHERE REQUIRED, FASCIA PANEL MUST BE FASTENED TO A SOLID WALL AND BE PERPENDICULAR TO THE FLOOR AND WALLS. HOISTWAY FASCIA IS NOT SELF-SUPPORTING FOR LONG, CONTINUOUS RUNS VOID OF ENTRANCES. ADEQUATE SUPPORT FOR THE FASCIA MUST BE PROVIDED.

NOTE LIFTING BEAM:


A 4000LB MIN SWL BEAM MUST BE PROVIDED IN THE OVERHEAD. BEAM TO BE POSITIONED AS SHOWN IN ELEVATION & PLAN VIEWS. FOR OVERHEAD OF 108" POSITION THE UNDERSIDE OF BEAM AT 104" & BEAM MUST BE TEMPORARY.

NOTE C

ALL INFORMATION IS SUBJECT TO CHANGE.
PLEASE REFERENCE OUR ON-LINE DRAWINGS AT



TABLE 3	DISCONNECT SIZE	TOE DELAY FUSE SIZE	VOLTS	PHASE	FLA
MOTOR & EQUIP.	60 AMPS	40 AMPS	230 volt	Single Phase	35.0 AMPS
CAB LIGHTS	15 AMPS	15 AMPS	115 V	Single Phase	

PIT RE-ACTION FORCE	
R3	8000 LBS
R4	3000 LBS
R5	5000 LBS

RAIL FORCES	
	
*R1	*R2
500 lbf	1570 lb
RAIL WEIGHT	80 lbf / ft

FOR TOTAL PULL-OUT FORCE ON RAIL BRACKET,
 $\#2 \times 720 = 1440 \text{ lbf}$
 FOR LOCAL APPLICATION OF PIT LOAD,
 R1 MUST BE DOUBLED.

RESIDENTIAL ELEVATOR
ZENITH MODEL 36X54 TYPE 1L

CUSTOMER:	DATE:	THE INFORMATION EXCLUDED HEREON IS THE EXCLUSIVE PROPERTY OF  AND MAY NOT BE USED BY OTHERS WITHOUT PRIOR WRITTEN CONSENT	 SHEET # 1 / 1
PROJECT:	ISSUANCE DATE:		
LOCATION:	COMPLETED BY:		