

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010063-R4
DATE: 11/17/2009
CERTIFICATION PROGRAM: Structural
COMPANY: American
CODE: 1582-1
REVISION DATE: 07/19/2016

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
American Skylights 1218 Corporate Drive East Arlington, TX 76006	Series "SFD-100" Aluminum Polycarbonate Double Domed Skylight Configuration: O Inner Dome: 1/8" Thick Polycarbonate Outer Dome: 1/8" Thick Polycarbonate Frame: W-1327mm(52.25") H-2546mm(100.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S. 2/A440-05 ASTM E1886-02/E1996-02 TAS 201/202/203-94	SKP-HC100 1327 x 2546 (52 x 100) Design Pressure: +100/-100 psf Wind Zone 4-Missile Level D Large Missile Impact Rated

Product Tested By: Architectural Testing, Inc.
Report No: 81599.01-801-18/81599.02-801-18/81599.03-801-44
Expiration Date: **September 30, 2019**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122