

# Certificate

On 23<sup>rd</sup> March 2007 Eurofins Environment A/S received a sample of a coating for porous mineral construction products with the name

## Protectosil<sup>®</sup> ANTIGRAFFITI Degussa GmbH

The emissions were tested according to the AgBB-scheme (AgBB - Committee for Health-related Evaluation of Building Products) with additional sampling for methanol. Sampling, testing and evaluation were performed according to ISO 16000-6, ISO 16000-9, ISO 16000-11, ISO 16017-1 in the latest versions, see test report no. 758996B.

### Evaluation of the test result according to AgBB guidelines:

---

- Carcinogenic substances were not detectable after 3 and after 28 days.
  - The sum of VOC ("TVOC") after 3 days was below the limit of 10 mg/m<sup>3</sup>.
  - The sum of VOC ("TVOC") after 28 days was below the limit of 1 mg/m<sup>3</sup>.
  - The sum of SVOC after 28 day was below the limit of 0.1 mg/m<sup>3</sup>.
  - After 28 days the value R was calculated from the detected VOC with single concentrations above 5 µg/m<sup>3</sup>. This value R was below the limit of 1.
  - The sum of VOC without LCI-value after 28 days was below the limit of 0.1 mg/m<sup>3</sup>.
  - Methanol was not detectable after 1, 3 and 28 days.
- 

**The tested product complies with the requirements of AgBB (September 2005) for use in the indoor environment.**

1<sup>st</sup> June 2007



---

Thomas Neuhaus  
Environmental Engineer



---

Inge Bondgaard  
M.Sc. (Chemistry)

Eurofins Environment A/S  
Smedeskovvej 38  
DK-8464 Galten /  
Denmark

Tel +45 70 22 42 66  
Fax +45 70 22 42 55